

Elaflex hose certificate / 10 years / Conductivity and pressure test

ELAFLEX 
INSPECTION CERTIFICATE 3.1
acc. to EN 10204:2004

Purchaser:

Order No.:
Order Date: 15.11.19
Confirmation No.: 1911031542
Confirmation Date: 19.11.19

Article and quantity:
2 x 20 m HC 65 C "Yellow Star"
both sides assembled with:
VC 55-21/ BSP 5m

Serial number: 31042/1 1-2
Assembling date: 14.1.19
Hose prod. no.: 207920
Hose prod. date: 14.1.19

max. working pressure: PG 20 bar

Pressure test:
Above hoses were tested at 40 bar / 10 min. Test medium: water. No leakages or faults were found.

Electrical conductivity:
The electrical conductivity was tested. The electrical resistance between the couplings, measured at the couplings, was recorded as:
31042/1 1-2 from 21400 Ohm to 22300 Ohm

Inspector: 20715 807 208

Result:
Regarding the pressure resistance and electrical conductivity above hoses correspond to the requirements of the ISO 1825 / EI 1529 and the agreed conditions of the order (conversion target: 20 bar ~ 300 psi / 40 bar ~ 600 psi)

Hamburg, the 25.11.19

Manager
representative

Sales

ELAFLEX - Garmes/Eliess GmbH, Schmuckenburgallee 121, 22625 Hamburg
Tel. +49 (40) 540 90 5-0 - Telefax +49 (40) 540 90 5-47

Product codes:

Product attributes:

Reference:
PC022-00007
EAN13: -
UPC: -

Product description:

Aviation hose compliance certificate to ISO 1825 / EI 1529 for: - Pressure test at 40 bar for 10min
- Electrical continuity This certificate is compliant with the Hazardous goods transportation agreement (ADR). It is valid for 10 years on every aviation fuelling site in France and in a foreign country.